

## Scope of accreditation

### Testing according to SS-EN ISO/IEC 17025:2018

Intertek Semko AB

Västerås

Accreditation number

1003

A000426-003

## Electrical testing

### Electrical quantities

| <i>Method</i> | <i>Parameter</i> | <i>Material</i> | <i>Flex</i> | <i>Type of flex</i> | <i>Field</i> | <i>Note</i>            |
|---------------|------------------|-----------------|-------------|---------------------|--------------|------------------------|
| EN 60947-2    |                  | Switchgear      | Yes         | 2                   | No           | Max test current 10 kA |
| EN 60947-3    |                  | Switchgear      | Yes         | 2                   | No           | Max test current 10 kA |
| EN 60947-4-1  |                  | Switchgear      | Yes         | 2                   | No           | Max test current 10 kA |
| EN 60947-4-2  |                  | Switchgear      | Yes         | 2                   | No           | Max test current 10 kA |
| EN 60947-5-1  |                  | Switchgear      | Yes         | 2                   | No           | Max test current 10 kA |
| IEC 60947-2   |                  | Switchgear      | Yes         | 2                   | No           | Max test current 10 kA |
| IEC 60947-3   |                  | Switchgear      | Yes         | 2                   | No           | Max test current 10 kA |
| IEC 60947-4-1 |                  | Switchgear      | Yes         | 2                   | No           | Max test current 10 kA |
| IEC 60947-4-2 |                  | Switchgear      | Yes         | 2                   | No           | Max test current 10 kA |
| IEC 60947-5-1 |                  | Switchgear      | Yes         | 2                   | No           | Max test current 10 kA |

Changes in the scope of accreditation are in bold.

The accreditation also applies to the corresponding version of the international EN and ISO standards.

The scope of accreditation is flexible as specified in this decision. The accredited body must always retain a current list of the scope for which it is accredited.

#### Type of flexible scope

- 1: - Introduce new version of standard method and make editorial changes to non-standard method
- 2: - Introduce new version of standard method and make editorial changes to non-standard method - Introduce new version and modifications of non-standard method. The procedure must be equivalent - Introduce new parameter/component/characteristics - Introduce new measurement range - Introduce new material/new products/matrices - Introduce new method equivalent to methods already in the accreditation decision